



Steven Levy Enterprises, Inc.
1412 Pennsylvania
South Houston, Texas 77587
Phone: (713) 910-4337 Fax: (713) 910-2039

Steven Levy Enterprises, Inc. is accepting bids on behalf of our clients for the following material:

SLE 18-028

Electrical Equipment Sale

GE, Eaton, Siemens, Square D, ABB & MORE!

Sealed Bid Sale

Attention
 Google chrome or Firefox users.
 Please read special instructions
before entering data.

Bidder Information

Company: _____

(Signature)	(Printed Name)	(Date)	(Phone Number)
Inspected Surplus	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
(Check One)			

Subject material to be sold on "AS IS / WHERE IS" basis.
 Material is sold FOB Steven Levy Enterprises, Inc. located at 1412 Pennsylvania, South Houston, Texas.

Bid Close: Tuesday, August, 21st @ NOON

To inspect material or for additional information contact:

Steven Levy Enterprises, Inc. (713) 910-4337
 Inspection Time 7:30 - 3:00 M-F
 Available for inspection Immediately thru Bid Close
 We are happy to pick up out-of-town buyers at Hobby Airport (HOU)

Seller reserves the right to reject any and all bids. Only the successful bidder will be notified of awards. Payment is due upon notification of award. All sales will be charged sales tax unless resale tax exemption certificate accompanies payment or is on file with Steven Levy Enterprises, Inc. Equipment is to be removed from property within ten (10) days at buyer's expense. Seller description of material is best available information, seller provides no express warranties and/or guarantees as to the quantity, quality, and/or fitness for any use or purpose. Steven Levy Enterprises, Inc. encourages all bidders to inspect material prior to placing bids.

******PLEASE SUBMIT THIS COVER PAGE WITH ALL BIDS******

Please visit our web site www.slevysurplus.com for more available equipment.

SLE 18-028 Electrical Equipment Sale

Company: _____

Bidder: _____

Phone: _____

LOT #	Qty	Part Number	Description	Lot Bid
IIP1	4	h2004b-3	C-H C306 CLASS 20 O/L	\$
	3	h2011b-3	C-H C306 CLASS 20 O/L	
	3	h2013b-3	C-H C306 CLASS 20 O/L	
	2	h2024-3	C-H C306 CLASS 20 O/L	
	2	M-25018	TERMINAL BLOCK,CONTROL CABLE,,STATES TYPE NT TERMINAL BLOCK, M - WHITE MARKER STRIP WITH BLACK CENTER FOR ENGRAVING, 250 - SLIDING LINK/WITH STAINLESS STEEL SCREW, 18 - 18-POLE, FRONT-CONNECTED POTENTIAL, 50A/600V RATINGS FOR 250 SERIES.	
	9	2C50DL	ALTECH MINIATURE MOLDED CASE CIRCUIT BREAKERS, DIN RAIL MOUNTED, IP20 PROTECTION, RATED VOLTAGE:250VDC, C-TRIP CHARACTERISTIC, UL LISTED E329510	
	1	C103.0	SQUARE-D OVERLOAD HEATER, SINGLE HEATER, THERMAL UNIT	
	4	219XDX69P-125VDC	RELAY, STRUTHERS-DUNN 125VDC, 4PDT	
	7	CR104PLT82W	LIGHT,NON HAZARDOUS,INDOOR,LIGHT/GE,PUSH-TO-TEST, FULL VOLTAGE LED LAMP, 20VAC/DC, WHITE LENS, POWER SUPPLY PART NUMBER CR104PXG40	
	1000	DNF14-250FIM-M	PANDUIT MALE DISCONNECT	
	3	TEB122050WL	GE CB, TYPE TEB,2P,50A, LINE AND LOAD LUGS	
	15	CR104PLT82R	LIGHT,NON HAZARDOUS,INDOOR,LIGHT/GE,PUSH-TO-TEST, FULL VOLTAGE LED LAMP, 120VAC/DC, RED LENS, POWER SUPPLY PART NUMBER CR104PXG40	
	4	H2109B-3	C-H C306 CLASS 10 O/L	
	2	H2108B-3	C-H C306 CLASS 10 O/L	
	4	H2005B-3	C-H C306 CLASS 20 O/L	
	1	H2107B-3	C-H C306 CLASS 10 O/L	
	4	2966278	RELAY MODULE/PHOENIX CONTACT	
	46	3038778	FUSE MODULAR TERMINAL BLOCK, PHOENIX,	
	8	T5A3040U	DISCONNECT SWITCH/EATON,	
	15	1492-EBJ3	A-B END BARRIER FOR TB	
10	1492-CJJ5-2	CENTER JUMPER, JUMPER BRIDGE, SCREW-IN TYPE, FOR TERMINAL BLOCK 1492-J3, 2-POLE, 50/PKG.		

LOT #	Qty	Part Number	Description	Lot Bid
IIP2	10	BU-5200-A-4-0	BNC,FEMALE BREAKOUT/WIRE	\$
	17	PS5R-VE24	IDEC 90W THIN POWER SUPP	
	67	1872-1A	STANDOFF INSULATOR	
	5	0282A2817P001	ARM LH* (MK FM B3501P1)	
	100	2240	HARDWARE,FASTENER,STANDARD,1-1/4 SNAP BUSHING FROM HEYCO	
	84	40301014	OBSOLETE, USE 40301032....WASHER, SEAL, 1/4", 5/8 O.D. X 1/8" THICK, 18-8 STNLS STL	
	5	5115-87-SPP015	RETAINING RING	
	100	85985K26	Rigid Plastic Locking Plug, Fits 1-3/16" ID, 1-5/16" Head Diameter	
	7	94887a123	LOW-PROFILE BINDING POST 18-8 STAINLESS STEEL 3/16-1/4 MATERIAL	
	2	6071K14	YOKE END, FEMALE, STEEL	
	2	R151018P2154	PIN	
	6	4YD86	PLASTIC/GUARD,GRAINGER,	
	2	1220250000	D-SERIES DRW / DRH, Relay base, No. of contacts: 3 CO contact, Continuous current: 16 A, Screw connection	
	30	RHRU7540	DIODE, BLOCKING, INTERSIL, HYPERFAST WITH SOFT RECOVERY	
	1	YA8C2LN	LUG, #8 AWG, DOUBLE HOLE, 1/2" STUD, 1.75 SPACING, STD BARREL (BURNDY YA8C2LN)	
	2	1220260000	D-SERIES DRW/DRH, RETAINING CLIP	
2	1174650000	D-SERIES , FREE WHEEL DIODE, RATED CONTROL VOLTAGE: 6-230VDC, PLUG IN CONNECTION		
IIP3	1	560-801	INSTRUMENT TRANSF. -1 CT	\$
	7	Eaton Breakers	circuit breaker	
	12	Square D Breakers	circuit breaker	
	2	Siemens Breakers	circuit breaker	
	1	ABB Breakers	circuit breaker	
IIP4	45	Ge Breakers	circuit breaker	\$
IIP5	5	785-750	ITI CT 75/5A, C20	\$
	6	115-202	CT/ITI 2000:5A 50-400HZ	
	6	110-601	CT/ITI 600/5A 25-400HZ	
	8	189-005	CT/ITI, WOUND PRI., MODEL	
IIP6	3	CAT #780-101	Instrument Transformer Current Transformer	\$
	17	110-801	CT/ITI 800/5A 50-400HZ	
IIP7	1	PTG3-2-60-242FF	ITI PT 2400/120V 60HZ	\$
	1	C0200E2AFB	Control Transformer 200VA 50/60 Hz	
	4	P21878	SNC Transformer P/N: P21878 240V 50/60 Hz	

LOT #	Qty	Part Number	Description	Lot Bid
IIP8	2	850EP5NNS5HNNAAN GAPCB2ESNBN	RELAY,PROTECTION,MULTIFUNCTION,850 FEEDER PROTECTION RELAY	\$
	4	mmbc17000093 (GE PART, NO POWELL LABEL)	MM300-GEHS1CADCXX	
	2	751A11DCD1D74851320	SEL-751A FEEDER PROTECTION RELAY	
	1	35303B0DX211A0XXXXXX	RELAY,PROTECTION,MULTIFUNCTION,RTAC SEL-3530	
IIP9	6	YA382N-FXB	LUG,POWER CABLE > 12,,BURNDY LUG	\$
	34	YA36-2N-FXB	BURNDY Cu Comp Terminal Flex Cond(Telecom), 2 Hole/W/O/InspWindow, 444.4 kcmil (1100/#24) DLO, 600 V-35 kV, 1/2" Stud, 1.75" Spacing, Lng bbl, Belled End	
	18	KC34	BURNDY SERVIT POST, 3/0 AWG-500MCM STRANDED CONDUCTORS. 3/4" SILICON BRONZE NUT	
IIP10	4	APJ6485	CROUSE-HINDS/COOPER 60A 3W-4P	\$
IIP11	3	24PB38D	SWITCH/PUSHBUTTON,CONTROL,CONTROL SWITCH, ELECTROSW	\$
	1	7012PA	RELAY,DISCRETE,TIME DELAY,7000 SERIES, 1 - ON-DELAY, 2 -2 FORM C CONTACTS, P - 125VDC COIL VOLTAGE, A - TIMING RANGE FROM 0.1 TO 1 SECOND.	
	2	250-240-LSLS-UL	METER,SINGLE FUNCTION,ANALOG,0-5A SELF CONTAINED 25-400HZ, IRON VANE, PIVOT AND JEWEL, UL	
	2	2438D	24 CB SW TRIP CLOSE, ELECTROSWITCH	
	3	74204D-001	ROTARY SWITCH/ELECTRO-	
	1	7022AD	TIMING REL/AGASTAT	
IIP12 (Continued Next Page)	3	AS0094500	SURGE SUPPRESSOR,TVSS,,ARBITER SYSTEMS, INC.,	Lot IIP12 Continued Next Page
	11	280612-1	HINGE,S646411,FIXED SPUN,	
	12	KUP-17A19-120	RELAY / POTTER-BRUMFIELD,	
	2	209-609	TERMINAL BLOCK,MARKING STRIP,,MARKING STRIP/WAGO,	
	6	201456	FIXED BRIDGE, PHOENIX,	
	6	047706.3MXP	FUSE,LOW VOLTAGE,,500VAC/400VDC,SLO-BLO,5X20MM,6.3A	
	8	1052028:0021	PHOENIX STRIP MARKED21-30	
	3	1492-M5X5	MARKER CARD, TERMINAL BLOCK MARKING STRIPS, SNAP-IN TYPE, 200/CARD, 5 CARD/PKG.	
	18	1053027:0011	TERMINAL BLOCK LABEL 11-20	
	1	60164P01	COLLAR	
	1	90293A316	ALUMINUM T-HANDLE PUSH BUTTON QUICK RELEASE PIN 3/8" DIAMETER, 3-1/2 IN. USABLE LENGTH	
	1	1000-U140	EMKA, 3 POINT CAM (MAGNUM)	
	1	1500070201P801	FUSE AND PRIMARY BUSHING SPANNING WRENCH	
	12	2810MT	FIBER OPTIC TRANSCEIVER	
	1	50006P01	BEAM SPACER	
	4	F2HDJ62.5STST-005	62.5/125 MICRON MULTIMODE FIBER-OPTIC CABLE HEAVY DUTY JACKET 2 FIBERS ST CONNECTORS BOTH ENDS, 5 FEET LONG	
9	10-NAMEPLATE	ELECTROSWITCH SERIES		
8	28282P000000277	MOC ACTUATORS CONNECTOR		

LOT #	Qty	Part Number	Description	Lot Bid
IIP12	20	0824962/31-40	TERMINAL BLOCK,MARKING STRIP,,TERMINAL MARKING STRIPS/	\$
	1	CCH-BLNK	CORNING CCH CONNECTOR PANEL, BLANK ADAPTER PANEL	
	8	AGC-10	10 AMP FUSE,1 1/4" X 1/4, 250VAC	
	6	1722A44	MCMaster CARR TOOL HOLDER FOR DIA. FROM 1" TO 1-7/8"	
	4	CCH-CP12-25T	FIBER OPTIC CONNECTOR,	
	18	371D956H10	3P PULL APART TERMINAL BLOCK 40A 600V 8-32 AWG	
	8	1-480698	AMP PLUG 2P MALE	
	2	209-608	MARKING STRIP/WAGO, 101-	
IIP13	3	STW0C2NW01	LED EXTERIOR LIGHT/DUROSITE,	\$
IIP14	2	CAP-75	MOUNTING HOOD, APPLETON, PENDANT TYPE FOR CMLED EXPLOSION PROOF TYPE LED LIGHT FIXTURE	\$
	3	HPWM70P	EXTERIOR LIGHT. COOPER-LUMARK, 70W HPS WITH PHOTOCELL,	
	2	G-AM271L-MT-1/2	FLOODLIGHT/APPLETON/EGS	
	6	LTXW4	LED LIGHT FIXTURE MOUNTING BRACKET	
	19	PS-5362-GRY	PASS & SEYMOUR RECEPTACLE, 20A/125V,	
	3	H2-JB	PCR,FIRE,DETECTOR HYDROGEN,STEEL JUNCTION BOX FOR HYDROGEN DETECTOR.	
IIP15	3	LU100/MED	100WATT HPS LAMP	\$
	2	8836GNK	B-LINE, WIREWAY, B-LINE, NEMA 1	
	2	88ENK	B-LINE, WIREWAY	
IIP16	23	WIUC10-C	WEATHERPROOF WHILE-IN-USE	\$
	32	TRM2	SHAWMUT-2A 250V FU-MCC	
	198	ATMR1-1/2	PRI FU 1-1/2AMP R GE	
	6	ATMR5	PRI FU 5 AMP R GE	
	8	FNM-1/10	FUSE, BUSSMANN, FNM TYPE, 1/10AMP, 13/32" X 1-1/2", TIME DELAY, 250VAC RATED	
	24	TRM1-6/10	SHAWMUT-1.6A 250V FU-MCC	
	2	AJT15	15A CLF,CLASS J TIME	
	6	TR15R	GOULD-SHAWMUT TRIONIC	
	6	AJT3	3A CLF,CLASS J TIME DELAY	
IIP17	10	AJT15	15A CLF,CLASS J TIME	\$
	46	USCC3	FUSE HOLDER, GOULD	
	2	9F60DJE015	CLF/EJ01 8250V/50KAIC 15E	
IIP17	2	5CLE-400E	CLF/CLE-2 5500V/50KAIC	\$
	1	5BHLE-125E	FUSE HLE-125E 5.5KV BOLT-IN TYPE, EATON C-H	

LOT #	Qty	Part Number	Description	Lot Bid
IIP18	100	402902G00	PIEDMONT SLEEVE-BUS	\$
	5	A-1102-G	SWITCH.FILNOR	
	90	276-4	TUBULAR HEATER 250W/250V	
	1748	3044571	Phoenix Feed-through Terminal Block, UT 4-Quattro Series,	
IIP19	2	BZ-50	ELECTRICAL COMPONENT, TRANSMITTER,, UNIVERSAL POWER PACK FOR OCCUPANCY SENSOR, 24VDC	\$
	9	RPLH30-02	ORANGE BULB TO USE WITH RPLH30-02-02-03.	
	24	RPLL30-CAF	CAP TO USE WITH RPLH30-02-02-03.	
	7	FVPTT120LG-IPBCGN	LIGHT, NON HAZARDOUS, INDOOR, C3CONTROLS PUSH-TO-TEST INDICATING LIGHT, FULL VOLTAGE 120VAC/DC, GREEN LED/GREEN LENS, BLACK POLYESTER CLAMP RING	
	9	FVPTT120LP-IPBCRD		
	9	SS02-SHWE	C3CONTROLS 2 POSITIONS SELECTOR SWITCH OPERATOR ONLY	
IIP20	12	140-500	CT/ITI 50/5A FOR GF	\$
IIP21	6	785-151	Current Transformer	\$
IIP22	5	ICH-06P	FIBER CONNECTOR HOUSING/CORNING	\$
IIP23	23	690c950h01	SWITCHGEAR, LV SWITCHGEAR, KIT, WESTINGHOUSE, BARRIER	\$
IIP24	6	AS1428-001	ELECTRICAL COMPONENT, OTHER, COMPONENT, OTHER,, ROOF BUSHING 4000AMP 2-3/8" CONDUCTOR, AIR-AIR.	\$
IIP25	254	U3-32-338-19	WATLOW TUBULAR HEATER 240V/480V 500W/2000W, UR	\$
IIP26	351	02-002-022	(2 pallets) INSULATOR CAST CYCLO 15KV	\$
IIP27	12	5ACLS-18R	FUSE/CLS-18R, C-H, 5KV, 390A	\$
IIP28	70	51447p04	BUS SUPPORT INSULATOR - 4000A - 63KA POW-FTB-8464 DF	\$
IIP29	12	785-SD-24822-6	CT/ITI 1200:5A MR C360	\$
	3	CT202-201	AMRAN CURRENT TRANSFORMER 600V, 200:5A RATIO, 10KV BIL, +/- 1 PERCENT. 5.0 VA BURDEN	
IIP30	3	CSD30208	C-SD30208 HOFFMAN ENCLOSURE	\$
IIP31	8	PTW5-1-110-1322F	(3 pallets) PT/ITI, 15KV, 13200/120V	\$
IIP32	8	PT6-1-125-1442	(4 pallets) POTENTIAL TRANSFORMER/ITI	\$
IIP33	1200	P101-2103	NON METALLIC PART, PLASTIC / RUBBER, GASKET, VIEW WINDOW GASKET	\$
IIP34a	34	WN232AUNVEB81U	INTERIOR LIGHT, WITH ACRYLIC WRAPAROUND DIFFUSER,	\$
IIP34b	100	WN232AUNVEB81U	INTERIOR LIGHT, WITH ACRYLIC WRAPAROUND DIFFUSER,	\$
IIP35	6pcs	EPC20-200-800E07T	ROOF BUSHING, 15KV 4000A, 110KV BIL, CYCLO. EPOXY UV- EXPOSED,	\$
IIP36	1	9T83B2673	XFMR, GE, 50KVA, 1PH, 3W, HIGH-EFFICIENCY	\$
IIP37	340'	N70003	#1940 CHANNEL UTR, 2-9/16X4-9/16X9/32 GPO-3 (location: yard)	\$
TAKE ALL LOT IIP1 - IIP37				\$